

Log No. 98314
 Permit No. _____
 Basin 070

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44408

1. OWNER Cyanco, Walter Wester ADDRESS AT WELL LOCATION 5505 Cyanco Drive Winn NV 89445 #
 MAILING ADDRESS 5505 Cyanco Drive Winn, NV 89445 N 40° 55.867' W 117° 52.101' Elev 4332
 2. LOCATION SW 1/4 SW 1/4 Sec. 6 T. 35 S. R. 37 E. Humboldt County
 PERMIT NO. Domestic 13-41-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blow Sand		0	3	3
Sand		0	15	15
Clay Brown		15	70	55
Sand + Fine Gravel		70	100	30
Clay		100	110	10
Fine Gravel	yes	110	120	10
Brown Clay		120	130	10

N 40° 55.867'
 W 117° 52.101'
 Elevation 4332

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 124 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 130 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1 85</u>	<u>±1</u>	<u>124</u>

Perforations:
 Type perforation Factory cut
 Size perforation 3/32 x 4
 From 104 feet to 124 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 124 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60.1 °F Quality Fair

Date started Nov 6 2003
 Date completed Nov 8 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>34</u>		<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson & Sons Drilling Contractor
 Address 10760 So. Grass Valley Rd Contractor
Winn NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed [Signature]
 _____ Driller performing actual drilling on site or contractor
 Date Nov 14 2003