WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92324
Permit No.
Basin 070

NOTICE OF INTENT NO. 41539

1. OWNER Cyanco
MAILING ADDRESS 5505 Cyanco Drive
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION Plant
N 40° 55.867 W 117° 52.101

2. LOCATION SW ¼ SW ¼ Sec. 6 T. 35 N/S R. 37 E. Humboldt County
PERMIT NO. Issued by Water Resources | Parcel No. 13-141-02 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Trip in hole Determine TD 100'				
perforate with Air Acutated				
perforator From 100' To 40'				
Pump Abantowite Slurry				
15 Sacs				
Add Native material Bring Level				
To 20' Cement From 20' To				
Surface				
4 Batches 12. Sacs 14+ lbs Per Gallon				

RECEIVED 03 NOV 18 AM 10:57 STATE ENGINEER'S OFFICE

Date started Nov 8 2003
Date completed Nov 8 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	+1	100'

Perforations:
Type perforation Peep Hawk 1/4 Slot
Size perforation
From 100' feet to 40' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling Contractor
Address 10760 Grass Valley Rd Contractor
Winn, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources the on-site driller 2083
Signed ____ By driller performing actual drilling on site or contractor
Date Nov 14. 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627