

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



office use only
Log No. 92332
Permit No.
Basin 110C

NOTICE OF INTENT NO 52835

1. OWNER **Esequiel Moya**
MAILING ADDRESS **2010 West Ave.**
Lancaster, NV

ADDRESS AT WELL LOCATION **Lucky Boy Rd.**

2. Location **NW 1/4 SW 1/4 Sec 24 T 7N R 29E Mineral County**
PERMIT NO. **PARCEL NO. 06-651-08** SUBDIVISION NAME

3. WORK PERFORMED
 New Well Replace Recondition
Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
Municipal/Industrial Monitor Stock

5. WELL TYPE
Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG		0	43	43
Red and white Rocks		43	81	38
Granite		81	117	36

RECEIVED
04 MAR - 1 AM 11:14
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Depth Drilled	117 feet	Depth Cased	117 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
10 5/8 inches	0 feet	50 feet	50 feet
8 3/4 inches	50 feet	117 feet	117 feet
			feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	117

Perforations:

Type Perforation	Factory	Size perforation	From	To
	3/32 x 3"		97 feet	117 feet
			feet to	feet
			feet to	feet
			feet to	feet
			feet to	feet

Surface Seal YES No
Depth of Seal 50 feet
Pumped Poured
Gravel Packed: Yes No
From 50 feet to 117 feet

Seal Type:
Neat Cement
 Cement Grout
Concrete Grout

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow 0 GPM 0 P.S.I.
Water Temperature cold Degrees F Quality

Date started **2-11-04**
Date completed **2-12-04**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)			Time (hours)
50	100			
100+	117			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date **2-20-04**