

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 92341
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **26089**

1. OWNER DANIEL & YVONNE MACNICOLL ADDRESS AT WELL LOCATION 4771 MELISSA
 MAILING ADDRESS 4771 MELISSA
PAHRUMP, NV

2. LOCATION SE 1/4 SE 1/4 Sec. 2 T 21 N/S R 53 E NYE County
 PERMIT NO. _____ Parcel No. 44-082-01 Subdivision Name MANKO
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	35	35
CALICHE		35	55	20
CLAY		55	77	22
CALICHE	WB	77	85	8
CLAY		85	105	20
CALICHE	WB	105	115	10
CLAY		115	135	20
CLAICHE	WB	135	148	13
CLAY		148	156	8
CALICHE	WB	156	160	4

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10.25 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	160

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From <u>100</u> feet to <u>160</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 67 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 3/8/04

Date started 3/5/2004, 19____
 Date completed 3/8/2004, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

DCNR/DWR
 RECEIVED
 MAR 15 2004

LAS VEGAS OFFICE