WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92343
Permit No. 69110
Basin 212

NOTICE OF INTENT NO. 25601

1. OWNER DESERT OAKS HOMES
MAILING ADDRESS CIMARRON & CAMERO
LAS VEGAS, NV

ADDRESS AT WELL LOCATION CIMARRON & CAMERO

2. LOCATION SE 1/4 NW 1/4 Sec. 16 T 22S N/S R 60 E CLARK County
PERMIT NO. ~~[illegible]~~ 69110 (Issued by Water Resources) | 176-16-201-009 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & GRAVEL		0	600	600
CEMENTED GRAVEL		600	660	60
GRAVEL & SAND	WB	660	680	20
CEMENTED GRAVEL		680	820	140
GRAVEL	WB	820	850	30
CEMENTED GRAVEL		850	880	30
LINESTONE	WB	880	900	20

DCNR/DWR
RECEIVED
MAR 1 1 2004
LAS VEGAS OFFICE

Date started 2/9/2004 , 19__
Date completed 2/25/2004 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	900	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	900

Perforations:
Type perforation FACTORY SAWCUT
Size perforation 1/8 X 3
From 780 feet to 800 feet
From 820 feet to 840 feet
From 880 feet to 900 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 900 feet

9. WATER LEVEL
Static water level 660 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dr (By driller performing actual drilling on-site or contractor)
Date 2/25/04

USE ADDITIONAL SHEETS IF NECESSARY