

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 92344
 Permit No. 35314
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25898

OWNER WULFENSTEIN CONSTRUCTION ADDRESS AT WELL LOCATION 141 N. SIERRA VISTA CR.
 MAILING ADDRESS 141 N SIERRA VISTA CR. EAST EAST
PAHRUMP, NV

2. LOCATION S 1/4 SE 1/4 Sec. 8 T 20S N/S R 53 E NYE County
 PERMIT NO. 35314 Issued by Water Resources Parcel No. 36-061-50 RANCHO VISTA UNIT 3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other Municipal/Industrial

4. PROPOSED USE
 Irrigation Test Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-----------------------|--------------|------|-----|-----------|
| 8IN CASED WELL | | | | |
| CLAY | | 0 | 110 | 110 |
| CALICHE | WB | 110 | 125 | 15 |
| CLAY | | 125 | 130 | 5 |
| CALICHE | WB | 130 | 165 | 35 |
| CLAY | | 165 | 178 | 13 |
| CALICHE | WB | 178 | 185 | 7 |
| CLAY | | 185 | 215 | 30 |
| CALICHE | WB | 215 | 220 | 5 |

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 110 Feet
7 7/8 Inches 110 Feet 220 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>4.5</u> | <u>2.06</u> | <u>.236</u> | <u>0</u> | <u>220</u> |

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

| | | |
|------|--------------------|-----------------|
| From | <u>120</u> feet to | <u>200</u> feet |
| From | feet to | feet |
| From | feet to | feet |
| From | feet to | feet |
| From | feet to | feet |

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal EXISTING

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 0 feet to 220 feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063

Signed Ken Tary
 By driller performing actual drilling on-site or contractor
 Date 2/20/2004

Date started 1/27/2004, 19
 Date completed 1/30/2004, 19

7. WELL TEST DATA

| TEST METHOD: | Draw Down (Feet Below Static) | | Time (Hours) |
|-----------------------------------|-------------------------------|--|--------------|
| | G.P.M. | | |
| <input type="checkbox"/> Bailor | | | |
| <input type="checkbox"/> Pump | | | |
| <input type="checkbox"/> Air Lift | | | |