

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 92403
 Permit No. _____
 Basin 047

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54350

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER KEVIN SMITH
 MAILING ADDRESS P.O. BOX 19
WELLS, NV 89835

ADDRESS AT WELL LOCATION ANGEL LAKE ROAD

2. LOCATION NE 1/4 SW 1/4 Sec. 8 T 37N
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. 008-340-030

N/S R 62E E ELKO County
TRACT OF LAND
 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
CLAY		2	80	78
VOLCANIC ROCK		80	120	40
SILTSTONE	220	120	240	120
HARD ROCK		240	260	20

Sealed with 22 bags of 3/8 holeplug and 3 bags of cement

8. WELL CONSTRUCTION

Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>260</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>260</u>

Perforations:
 Type perforation MILLSLOT
 Size perforation 1/8 X 3
 From 240 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 260 feet

9. WATER LEVEL

Static water level 159 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 97 °F Quality UNK

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC
 Contractor

Address P.O. BOX 850
 Contractor

ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed Dani Reem
 By driller performing actual drilling on-site or contractor

Date 10/28/2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60</u>		<u>3</u>

RECEIVED
 10 NOV 7 AM 10:38
 STATE ENGINEERS OFFICE