WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No: 92415
Permit No.
Basin 044

NOTICE OF INTENT NO. 50550 2nd 50547 1st

1. OWNER Queen Stake Resourses USA
MAILING ADDRESS Jerritt Canyon HC-31 Box 78
ADDRESS AT WELL LOCATION Queen Stake - Jerritt Canyon Mill

2. LOCATION NE ¼ NW ¼ Sec. 33 T. 41 N/S R. 54 E. ELKO County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Gravels		0'	100'	
Trace of H2O → 48'				
3 hrs. of cleaning water is clean.				
Flush Joint Sch. 40 PVC				

Date started 10-12 2003
Date completed 10-21 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 100' Feet Depth Cased 96' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0'	20'
8¾	20'	100'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	1.80	SCH. 40 PVC	0'	100'

Perforations:
Type perforation Horz. slot
Size perforation .080
From 100' feet to 40' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From feet to 35' feet

9. WATER LEVEL
Static water level 52' feet below land surface
Artesian flow NO G.P.M. ½ P.S.I. 100
Water temperature 49° °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Ward Weaver
Address (Contractor) 2305 Last Chance Rd.
ELKO, NV. 89801
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver
By driller performing actual drilling on site or contractor
Date 10-21-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627