

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 92432  
Permit No. ....  
Basin 95

NOTICE OF INTENT NO 51539

1. OWNER **Richard Dominguez**  
MAILING ADDRESS **715 Encanto**  
**Reno NV**

ADDRESS AT WELL LOCATION **715 Encanto**

2. Location **SE 1/4 SE 1/4 Sec 8 T 21N R 21E** **Washoe** County  
PERMIT NO. **PARCEL NO. 076-300-39** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE  
 New Well |  Domestic |  Rotary RVC  
 Replace | Irrigation | Cable  
 Deepen | Abandon | Other | Municipal/Industrial | Monitor | Stock | Air | Other | Mud

6. LITHOLOGIC LOG

Material	Water/Strata	From	To	Thick-ness
Sand.		0	3	3
DG & brown clay.		3	22	19
Soft limestone.		22	260	238
Black volcanic.		260	271	11
Fractured grante.		271	276	5
Black volcanic hard.		276	538	262
Fracture		538	539	1
Hard black volcanic.		539	1120	581
Fracture		1120	1121	1
Hard volcanic.		1121	1200	89

8. WELL CONSTRUCTION  
 Depth Drilled **1200** feet | Depth Cased **570** feet  
 HOLE DIAMETER (BIT SIZE)  
 From | To  
**11** inches | **0** feet | **68** feet  
**8 3/4** inches | **68** feet | **570** feet  
**6 1/2** inches | **570** feet | **1200** feet  
 CASING SCHEDULE  
 Size O.D. | Weight/Ft. | Wall Thickness | From | To  
 (Inches) | (Pounds) | (Inches) | (Feet) | Feet  
**6 5/8** | **12.94** | **188** | **+1 1/2** | **570**

Contacted owner on 1-19-94 about completing well. said he had no money at this time.

Perforations:  
 Type Perforation **Factory**  
 Size perforation **3/32 x 3"**  
 From **260** feet to **280** feet  
 From **530** feet to **570** feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal  YES No Seal Type:  
 Depth of Seal **53** feet Neat Cement  
 Pumped  Cement Grout  
 x Poured Concrete Grout  
 Gravel Packed:  Yes No  
 From **53** feet to **570** feet

Date started **9-23 -03**  
Date completed **11-1 -03**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		

9. WATER LEVEL  
 Static water level **250** feet below land surface  
 Artesian flow **0** GPM **0** P.S.I.  
 Water Temperature **cold** Degrees F Quality

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
 NV Contractors No. **14170**  
 NV Driller's Lic (on site) **1261-TI**  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date **11-12 -03**



DEPARTMENT OF CONSERVATION AND NATURAL RESOURCES  
DIVISION OF WATER RESOURCES

123 W. Nye Lane, Suite 246  
Carson City, Nevada 89706-0818  
(775) 687-4380 • Fax (775) 687-6972  
<http://water.nv.gov>

November 7, 2003

McKay Drilling, Inc.  
Steve McKay  
2290 Pioneer Drive  
Reno, NV 89509

RE: Request for suspension of drilling October 30, 2003, within Washoe County, Nevada.  
Local No. 084 N21 E21 08 Dd, APN 076-300-39

Dear Mr. McKay:

This will acknowledge your request for suspension of drilling, received by this office October 30, 2003. The well location is at 9260 Cordoba Boulevard in Sparks, Nevada, APN 076-300-39. Nevada Administrative Code (NAC) § 534.370 (5) allows for the suspension of drilling upon approval by this division.

Following our discussion as to the location and condition of the well authorization is here within granted to suspend drilling. The well must be secured pursuant to NAC § 534.370 (3).

**This authorization expires sixty (60) days from the date of this letter at which time the well must be completed pursuant to NAC § 534.360 or plugged and abandoned pursuant to NAC § 534.420.**

It is expressly understood this authorization does not relieve the operator of the permitting requirements of other state, federal and local agencies.

If you have any questions, please contact this office at (775) 687-4380 Extension 4.

Sincerely,

A handwritten signature in black ink, appearing to read "Tim Hunt".

Tim Hunt  
Well Supervisor

TH/jjs

cc: Richard Domingues  
Washoe County District Health  
Ken Stine – Reno District Health