

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25857

1. OWNER Shirley Scheeng ADDRESS AT WELL LOCATION 1/2 mile North of Robison Ranch Hwy 50
 MAILING ADDRESS Po Box 210 1 Delta, ut. 84624

2. LOCATION NW 1/4 SW 1/4 Sec. 20 T. 14 N. S. R. 70 E White Pine County
 PERMIT NO. 012-230-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay, sand, cobble		0	7	7
clay		7	13	6
sand gravel cobble		13	55	42
clay		55	70	15
sand, gravel, cobble	X	70	102	32
clay, sand		102	120	18
sand, cobble	X	120	135	15
clay		135	142	7
sand, gravel, cobble	X	142	168	26
clay		168	175	7

8. WELL CONSTRUCTION
 Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 175 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>18</u>	<u>.250</u>	<u>+2</u>	<u>175</u>

Perforations:
 Type perforation factory milled
 Size perforation 1/8 x 2 1/2

From 75 feet to 95 feet
 From 115 feet to 135 feet
 From 155 feet to 175 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 175 feet

9. WATER LEVEL
 Static water level 61.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 42 °F Quality Good

Date started Dec. 3, 2003
 Date completed Dec. 10, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>150'</u>	<u>2 hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Webber Drilling Contractor
 Address 2475 W. 3935 St. WVC, UT. 84119 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0025887
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238

Signed Bryan Anzalone
 By driller performing actual drilling on site or contractor

Date Dec. 20, 2003