WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92442
Permit No.
Basin 154

NOTICE OF INTENT NO. 49055

OWNER Noble Energy
MAILING ADDRESS 100 Glenborough
Houston, TX 77067

ADDRESS AT WELL LOCATION NEI Rattlesnake

2. LOCATION SW 1/4 NW 1/4 Sec. 26 T 22N N/S R 55E E White Pine County
PERMIT NO. OG-222 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LIGHT CREAM COLORED		0		
CLAY			8	8
BROWN CLAY		8	28	20
BLUE SAND/SOFT BLUE	X	84		
CLAY			96	12
HARD BLUE CLAY		96	180	84
BROWN GRAVEL & SAND	X	180	235	55

Date started 12/18/2003, 19__
Date completed 12/20/2003, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	45		4.5

8. WELL CONSTRUCTION
Depth Drilled 235 Feet Depth Cased 235 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	235	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	235

Perforations:
Type perforation mill slot
Size perforation 3/16 x 3
From 215 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 68
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 68 feet to 235 feet

9. WATER LEVEL
Static water level flowing feet below land surface
Artesian flow approx 25 G.P.M. 15 P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C FRTIG SR., DBA FERTIG DRILLING CO (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 1/19/2004

USE ADDITIONAL SHEETS IF NECESSARY