

REPORT NO. **A04.005**

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

**WELL DRILLER'S REPORT**

LOG NO. 92456  
PERMIT NO. \_\_\_\_\_  
BASIN 85

NOTICE OF INTENT NO. **51478**

1. OWNER Eric VanCleemput ADDRESS OF WELL 80 Pancho Villa Court  
MAILING ADDRESS 9517 Black Canyon Dr. Reno, NV 89506 Reno, NV 89506  
2. WELL LOCATION NW 1/4 SW 1/4 SEC. 31 T 21 R 21 E Washoe COUNTY  
PERMIT NO. \_\_\_\_\_ PARCEL NO. 076-390-41 SUBDIVISION NAME \_\_\_\_\_

3. TYPE OF WORK

New Well  Replace  Recondition  
 Deepen  Plug  Other

4. PROPOSED USE

Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE

Cable  Rotary  RVC  
 Air  Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Sand Brown Clay & Rock		0	20	20
Light Yellow Sandy Sticky Clay		20		
& Small Rock		20	30	10
Reddish Brown Sandy Clay		30		
& Small Rock Sand		30	70	40
Reddish Brown Sticky Sandy Clay		70		
& Small Rock		70	150	80
Lt. Greenish Brown Silty Clay		150		
& Small Rock		150	160	10
Coarse Sand Silty Clay		160	210	50
Coarse Sand Greenish Brown Silty Clay		210	245	35
Specs of Quartz Vol. Rock, Red		245		
Yellow Coarse Sand Silty Clay		245	300	55
Coarse Sands Smooth Rock		300		
& Specs of Greenish Sandy Clay	X	300	337	37

8. WELL CONSTRUCTION

Depth Drilled **337** Depth Cased **337**

HOLE DIAMETER (BIT SIZE)

**10 5/8** Inches **0** Feet **50** Feet  
**8 1/2** Inches **50** Feet **337** Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
<b>6 5/8</b>	<b>12.92</b>	<b>.188</b>	<b>+3</b>	<b>337</b>

PERFORATIONS:

Type Perforation **Factory** Size Perforation **3/32 x 3**  
From **297** Feet to **337** Feet  
From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

SURFACE SEAL:  Yes  No SEAL TYPE:  
Seal Depth **50**  Neat Cement  
 Cement Grout  
PLACEMENT METHOD:  Pumped  Concrete Grout  
 Poured  Bentonite

GRAVEL PACKED:  Yes  No  
From **50** Feet to **337** Feet

9. WATER LEVEL

Static Water Level **116'** Feet Below Land Surface  
Artesian Flow \_\_\_\_\_ GPM \_\_\_\_\_ PSI  
Water Temperature **Cool** F Quality **Clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**  
Address **675 Edison Way**  
**Reno, NV 89502**

DRILLER'S LIC. NO. \_\_\_\_\_  
NV. CONTRACTOR'S LIC. NO. **15291** ON SITE **2189**

Signed *Rogerenthal*  
By driller performing actual drilling on site or contractor  
Dated **January 20, 2004**

7. WELL TEST DATA

TEST METHOD  Bailer  Pump  Air Develop

GPM	DRAWDOWN	TIME (HRS)
<b>20+</b>		<b>2hrs.</b>

Notes:

RECEIVED  
 AQUA DRILLING & WELL SERVICE  
 675 EDISON WAY  
 RENO, NV 89502