

OFFICE USE ONLY
 Log No. 92492
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25552

1. OWNER John & Jennifer Wampole ADDRESS AT WELL LOCATION
 MAILING ADDRESS 800 N. Rainbow Blvd. Ste 208 Las Vegas, Nev. 89107 6675 Whispering Sands Dr
 2. LOCATION SW 1/4 NW 1/4 Sec 14 T. 19S N/S R. 60 E. Clark County
 PERMIT NO. 125-14-201-003 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Popcorn Caliche		0	35	
Caliche		35	60	
Popcorn caliche		60	145	
Caliche & Water	xx	145	160	
Reddish Clay & Sand		160	370	
Caliche & Water	xx	370	390	
Reddish Clay & Sand		390	710	
Caliche & Water	xx	710	755	

DCNR/DWR
 RECEIVED
 FEB 23 2004
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 755 Feet Depth Cased 755 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 755 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	50
6 1/2 PVC SRD			+1	755

Perforations:
 Type perforation Factory
 Size perforation .032 Sieve type
 From 715 feet to 735 feet
 From 635 feet to 655 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 125 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. Bonita Vista Contractor
Las Vegas, Nev. 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed VH Dimick
 By driller performing actual drilling on site or contractor
 Date 02-14-04

Date started 2/7/04, 20_____
 Date completed 2/14/04, 20_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)