

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 94620  
 Permit No. \_\_\_\_\_  
 Basin 870  
 NOTICE OF INTENT NO. 48634

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Gary & Terri Tompkins Family Trust ADDRESS AT WELL LOCATION 4675 W. Winnemucca Blvd  
 MAILING ADDRESS 9200 S. Beechcraft Blvd.  
Winnemucca, NV 89445

2. LOCATION NW 1/4 SW 1/4 Sec. 2 T 35N N/S R 37E E Humboldt County  
 PERMIT NO. 68512  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	
coarse sand		3	11	8
coarse sand & gravel		11	14	3
coarse sand & gravel 1		14		
inch			48	34
coarse to fine sand & gravel		48		
			64	16
sand & gravel w/clay layers		64		
			74	10
sand & gravel		74	171	97
sand & gravel w/clay		171	179	8
sand & gravel w/clay layers		179		
			210	31

RECEIVED  
 03 OCT 15 AM 11:54  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 210 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 210 Feet  
15 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10-3/4		.250	+2	100
8-5/8		.250	100	200

Perforations:  
 Type perforation mill slot  
 Size perforation .100  
 From 60 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 210 feet

9. WATER LEVEL  
 Static water level 22 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

Date started 10/1/03, 19\_\_\_\_  
 Date completed 10/2/03, 19\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, Nevada 89445  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2158  
 Signed Jerry Tompkins  
 By driller performing actual drilling on-site or contractor  
 Date 10/12/03

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>500</u>		<u>2 hrs.</u>	