WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92633
Permit No.
Basin 230

NOTICE OF INTENT NO. 25654

1. OWNER Donald & Dennis Boydston
MAILING ADDRESS P.O. Box 160
Amargosa Valley, Nv. 89020

ADDRESS AT WELL LOCATION
1894 Maverick St.
Amargosa Valley, Nv. 89020

2. LOCATION SW ¼ NW ¼ Sec. 15 T. 16 N/O R. 48 E. NYE County

PERMIT NO. ____ Issued by Water Resources | 19-551-37 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
snd. & gravel		0	95	95
brown cly.		95	105	10
snd.		105	115	10
snd. & gravel	1st	115	135	20
limestone		135	145	10
snd.		145	170	25
gravel + cly. layers		170	190	20
snd.		190	200	10
Bottom of well			200	

DCNR/DWR
RECEIVED
FEB 05 2004
LAS VEGAS OFFICE

Date started 1/9, 2004
Date complated 1/12, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	200
Surface Protective Casing:				
8	Steel	.188	0	7

Perforations:
Type perforation Machined
Size perforation GR.032 Screen: * 1/8" x 3" x 12"
From 120 feet to 180 feet
From 180 feet to 190 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. (Contractor)
Address H.C. 70 Box 543 (Contractor)
Amargosa Valley, Nv. 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed [signature] By driller performing actual drilling on site or contractor
Date 1/23/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627