

OFFICE USE ONLY  
 Log No. 92635  
 Permit No. \_\_\_\_\_  
 Basin 230

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25653

1. OWNER Clyde Butler ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3275 W. Ashland Ave. Fresno, Cal. 93722 Elm Circle Amargosa Valley, NV. 89020  
 2. LOCATION N 1/4 SW 1/4 Sec 20 T. 16 N. R. 49 E County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. 19-611-27 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Drill

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel & sand		0	80	80
Cemented gravel		80	100	20
Sand		100	125	25
Cemented gravel		125	135	10
gravel w/sand	1SF	135	150	15
fracture w/gravel layers		150	195	45
gravel w/sand	2nd	195	215	20
limestone		215	220	5
Bottom of well			220	

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>220</u>
<u>8</u>	<u>Steel</u>	<u>.188</u>		<u>7</u>

 Perforations:  
 Type perforation Machined  
 Size perforation 6R, 0.375 screen; # 1/8 x 3" every 12"  
 From 135 feet to 195 feet  
 From 195 feet to 205 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 220 feet

Date started 12/10/21  
 Date completed 12/14/21

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 126 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.1 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Cook Drilling Co. Contractor  
 Address H.C. 70, Box 543 Contractor  
Amargosa Valley, NV. 89020  
 Nevada contractor's license number issued by the State Contractor's Board 5376-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160  
 Signed Randy Johnson  
 By driller performing actual drilling on site or contractor  
 Date 12/14/21