WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92636
Permit No.
Basin 230

NOTICE OF INTENT NO. 25659

1. OWNER Bruce Greenhalgh
MAILING ADDRESS 4250 Capital View
Carson City, Nv 89701

ADDRESS AT WELL LOCATION 1700 S. Van Patten Ln.
Amargosa Valley, NV. 89020

2. LOCATION SW ¼ SW ¼ Sec. 12 T. 17 N R. 48 E. NYE County

PERMIT NO. _____ Issued by Water Resources | 19-621-05 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Snd. w/white cly. layers		0	60	60
limestone		60	74	14
small void-cly.	1st	74	87	13
limestone		87	97	10
Snd		97	120	23
limestone		120	130	10
tan cly.		130	155	25
snd. w/gravel	2nd	155	168	13
limestone		168	180	12
snd w/cly.		180	200	20
Bottom of Well			200	

DCNR/DWR
RECEIVED
APR 07 2004
LAS VEGAS OFFICE

Date started 3/6, 2004
Date completed 3/7, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	200
Protective Casing - Surface:				
8	steel	0.188		7

Perforations:
Type perforation Machined
Size perforation 6R, .032 Screen; 1/8 x 3, 4R *
From 100 feet to 160 feet
From *160 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. (Contractor)
Address H.C. 70, Box 543 (Contractor)
Amargosa Valley, Nv. 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed [signature]
By driller performing actual drilling on site or contractor
Date 3/31/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627