WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92666
Permit No.
Basin 212

NOTICE OF INTENT NO. 26051

1. OWNER American Pacific Corp
MAILING ADDRESS 3770 Howard Hughes Pkwy Ste 300 L.V. NV 89109

ADDRESS AT WELL LOCATION 200' W. of Gibson, 45' S. of American Pacific

2. LOCATION SE ¼ SW ¼ Sec. 11 T. 22 N/S R. 62 E Clark County

PERMIT NO. — (Issued by Water Resources) 178-155-11021 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel		0	8	8
Silty Sand		8	19	11
Silty Clay		19	45	26
Silt		45	73	28
Silty Sand		73	101	28
Silt w/some clay		101	126	25
Silty Sand		126	130	4
Sand		130	135	5
Silty Sand		135	179	44
Clayey Silt		179	200	21
Sandstone		200	202	2

DCNR DWR RECEIVED MAR 01 2004 LAS VEGAS OFFICE

Date started 1-28-04, 20
Date completed 1-29-04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 202 Feet Depth Cased 201 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 3/4 Inches		0 Feet	202 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 40 PVC	.020	0	161

Perforations:
Type perforation slotted PVC
Size perforation .020
From 161 feet to 201 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 152'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 157 feet to 202 feet

9. WATER LEVEL
Static water level 16.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Presonic (Contractor)
Address 419 E. Juanita #104 (Contractor)
Mesa AZ 85204
Nevada contractor's license number issued by the State Contractor's Board 0051765
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1941
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-26-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627