WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92671
Permit No.
Basin 163

NOTICE OF INTENT NO. 25230

1. OWNER ROLAND G. MONDRAGON
MAILING ADDRESS
ADDRESS AT WELL LOCATION JASPER AV. & PAIUTE ST. SANDY VALLEY NV.

2. LOCATION NW ¼ NW ¼ Sec. 25 T. 24 N/S R. 56 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 200-25-101-010 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	5	5
CLAY		5	18	13
CLAY + GRAVEL		18	24	6
CLAY		24	38	14
CALICHIE		38	44	6
CLAY		44	68	24
CALICHIE	W.B	68	72	4
CLAY		72	88	16
CALICHIE	W.B	88	91	3
CLAY		91	110	19
CALICHIE	W.B	110	115	5
CLAY		115	126	11
CALICHIE	W.B	126	133	7
CLAY		133	140	7

DCNR/DWR
RECEIVED
APR 07 2004
LAS VEGAS OFFICE

Date started 3-10, 2004
Date completed 3-13, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.33	.316	0	140

Perforations:
Type perforation SAW CUT
Size perforation 1/8" INCH BY 6 INCH
From 140 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 FT.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. (Contractor)
Address P.O. BOX 3505 PAHRUMP NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 3-16-2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627