

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25232

1. OWNER ADOLFO SALDIVAR ADDRESS AT WELL LOCATION NORITE AV. + PAUTE ST. SANDY VALLEY NV
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NW 1/4 Sec. 36 T. 24 N. R. 56 E. CLARK County
 PERMIT NO. 200-36-101-008 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	3	3
CALICHE		3	6	3
CLAY		6	28	22
CALICHE		28	32	4
CLAY		32	62	30
CALICHE	W.B	62	67	5
CLAY		67	84	17
CALICHE	W.B	84	88	4
CLAY		88	102	14
CALICHE	W.B	102	114	12
CLAY		114	129	15
CALICHE	W.B	129	135	6
CLAY		135	140	5

DCNR/DWR
 RECEIVED
 APR 07 2004
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 140 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>4.33</u>	<u>1.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation FINISH BY 6 INCH
 From 140 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 FT.
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 57 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.2 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO. Contractor
 Address P.O. Box 3505 PAHRUMP NV. Contractor
89041
 Nevada contractor's license number issued by the State Contractor's Board 46020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3-26-2004

Date started 3-22, 2004
 Date completed 3-26, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			