WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92676
Permit No. 67442
Basin 163

NOTICE OF INTENT NO. 25228

1. OWNER THOMAS L + DONNA LEEDS
MAILING ADDRESS
ADDRESS AT WELL LOCATION CLIACTZ AV. + ARTESIA ST. SANDY VALLEY NV.

2. LOCATION SW¼/NW¼ NE¼/NW¼ Sec. 6 T. 25 N/S R. 57 E. CLARK County
PERMIT NO. 67442 (Issued by Water Resources) 219-06-101-003 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
CALICHIE		6	10	4
CLAY		10	38	28
CALICHIE		38	42	4
CLAY		42	58	16
CALICHIE	W.B	58	63	5
CLAY		63	88	25
CALICHIE	W.B	88	95	7
CLAY		95	115	20
CALICHIE	W.B	115	120	5
CLAY		120	133	13
CALICHIE	W.B	133	140	7
CLAY		140	152	12
CALICHIE	W.B	152	162	10
CLAY		162	179	17
CALICHIE	W.B	179	185	6
CLAY		186	197	11
CALICHIE	W.B	197	200	3

Date started 3-1, 2004
Date completed 3-5, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.33	.316	0	200

Perforations:
Type perforation FACTORY SCREEN
Size perforation 8 INCH BY 3 INCH
From 200 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 200 feet to 50 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. (Contractor)
Address P.O. BOX 3505 PAHRUMP NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 3-8-2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627