

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT-NO 25226

1. OWNER JOHN + PEGGY ELLENBURG ADDRESS AT WELL LOCATION WOOD AV + POTOMAC ST.
 MAILING ADDRESS _____ SANDY VALLEY NV
 2. LOCATION SE 1/4 SW 1/4 Sec. 23 T. 24 N. R. 56 E. CLARK County
 PERMIT NO. _____ Parcel No. 200-23-401-023 Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	6	6
CLAY		6	32	26
Caliche		32	37	5
CLAY		37	58	21
Caliche		58	62	4
CLAY		62	82	20
Caliche	WB	82	87	5
CLAY		87	97	10
Caliche	WB	97	101	4
CLAY		101	118	17
Caliche	WB	118	123	5
CLAY		123	133	10
Caliche	WB	133	140	7

DCMR/DWR RECEIVED
 MAR 16 2004
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 3" INCH BY 6" INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50 FT.
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO Contractor
 Address P.O. Box 3505 Pahrump NV Contractor
89041
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Donnie Brown
 By driller performing actual drilling on site or contractor
 Date 3-11-2004

Date started 2-27 2004
 Date completed 3-8 2004

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	