WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92680
Permit No.
Basin 212

NOTICE OF INTENT NO. 25557

1. OWNER Jim Thompson (James Jr + Reese) ADDRESS AT WELL LOCATION
MAILING ADDRESS
VERDE WAY & CONQUESTADOR

2. LOCATION SW ¼ SW ¼ Sec. 31 T. 19S N/S R. 60 E. Clark County
PERMIT NO. (Issued by Water Resources) 125-31-401-017 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravel | | 0 | 15 | |
| Cemented Gravel | | 15 | 360 | |
| Gravel & Clay | | 360 | 550 | |
| Gravel & Water | XX | 550 | 565 | |
| Cemented Gravel | | 565 | 710 | |
| Gravel & Water | xx | 710 | 830 | |

UCNR/DWR
RECEIVED
MAR 2 5 2004
LAS VEGAS OFFICE

Date started 3/11/04, 20
Date completed 3/18/04, 20

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 830 Feet Depth Cased 830 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 1/4 Inches | | 0 Feet | 60 Feet |
| 9 7/8 Inches | | 60 Feet | 830 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | +2 | 830 |

Perforations:
Type perforation Factory
Size perforation .032
From 770 feet to 810 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 60
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [x] Concrete Grout
Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL
Static water level 517 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista St. (Contractor)
Las Vegas, Nevada 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 03-22-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627