

BH-3

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 92725

Permit No. _____

Basin 87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46104

1. OWNER George Brown, Commercial Property Services ADDRESS AT WELL LOCATION 499 E. Plumb Lane
 MAILING ADDRESS 14147 Lakeside Dr. Suite 104 Reno, Nevada 89502

2. LOCATION SW 1/4 SE 1/4 Sec. 13 T. 19 S. R. 19 E. Washoe County
 PERMIT NO. M/O - 1311 Issued by Water Resources Parcel No. D13-462-14 Subdivision Name Plumb Lane Plaza

3. WORK PERFORMED

New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Other Service

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0'	0.5'	0.5'
Light Brown Med. Moist		0.5'	2.5'	2'
Med. Plastic Sandy Clay		2.5'	4.5'	2'
Yellowish Brown, Moist, Medium Dense, Clayey Sand		4.5'	15'	10.5'
Light Brown, Medium Moist Silty Sand with Small Gravel		15'	22'	7'
Medium Yellowish Brown, dense, wet, poorly graded gravel	✓			
Medium Greenish Gray, wet, Medium Dense, poorly graded sand	✓			

8. WELL CONSTRUCTION

Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

From 0' To 30' Feet
 8" Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch. 40	0.474"	0'	20'

Perforations:

Type perforation Factory Cut

Size perforation 0.020"

From 20' feet to 30' feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout Best Chips

Depth of Seal 18'

Placement Method: Pumped Poured

Gravel Packed: Yes No

From 18' feet to 30' feet

9. WATER LEVEL

Static water level 15.5' feet below land surface

Artesian flow NO G.P.M. _____ P.S.I. _____

Water temperature _____ °F Quality _____

Date started 3-3- 2004

Date completed 3-3- 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Phillip Ciener for BOAT LONGYEAR Co. Contractor

Address P.O. Box 1000 32 Stokes Dr. Contractor
Dayton, NV 89403

Nevada contractor's license number issued by the State Contractor's Board 0010157

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148

Signed Phillip Ciener By driller performing actual drilling on site or contractor

Date 3-9-04