


BH-2

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. 92726

Permit No.

Basin 87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46104

1. OWNER George Brown, Commercial Property Services ADDRESS AT WELL LOCATION 499 E. Plumb Lane
MAILING ADDRESS 6147 Lakeside Dr. Suite 104 Reno, Nevada 89502

2. LOCATION SW 1/4 SE 1/4 Sec. 13 T. 19 N. R. 19 E. Washoe County
PERMIT NO. M/D-1311 Parcel No. 013-462-14 Subdivision Name Plumb Lane Plaza

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>		<u>0'</u>	<u>.5'</u>	<u>.5'</u>
<u>Brown, Moderately Moist, loose, sandy silt</u>		<u>.5'</u>	<u>6'</u>	<u>5.5'</u>
<u>Brown, Moist, loose Silty SAND</u>		<u>6'</u>	<u>18'</u>	<u>12'</u>
<u>Brown, Wet, higher plasticity Silty SAND</u>	<input checked="" type="checkbox"/>	<u>18'</u>	<u>30'</u>	<u>12'</u>

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)
From 0' To 30'
8" Inches 0' Feet 30' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>Sch. 40</u>	<u>0.474"</u>	<u>0'</u>	<u>20'</u>

Perforations:
Type perforation Factory Cut
Size perforation 0.020"
From 20' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 16' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Best Chips
Gravel Packed: Yes No
From 16' feet to 30' feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality

Date started 3-2- 2004
Date completed 3-2- 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer for Bost Longyear Co. Contractor
Address P.O. Box 1000 32 Stokes Dr. Contractor
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148
Signed Phillip E. Cramer
By driller performing actual drilling on site or contractor
Date 3-9-04

Plugged by well 100

124280