

BH-1

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 92728
Permit No.
Basin 87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46104

1. OWNER George Brown, Commercial Property Services ADDRESS AT WELL LOCATION 499 E. Plumb Lane
MAILING ADDRESS 6147 Lakeside Dr. Suite 104 Reno, Nevada 89502

2. LOCATION SW 1/4 SE 1/4 Sec. 13 T. 19 R. 19 E. Washoe County
PERMIT NO. M/P-1311 Issued by Water Resources Parcel No. 003-462-14 Subdivision Name Plumb Lane Plaza

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0'	0.5'	0.5'
Brown, Moderately Moist, Medium-Dense Sandy Silt		0.5'	5.5'	5'
Brown Mod.-Moist loose Silty SAND		5.5'	20'	14.5'
Gray wet loose poorly GRADED SAND	✓	20'	30'	10'

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet
HOLE DIAMETER (BIT SIZE)
From 8 Inches To 0' Feet
From 0' Feet To 30 Feet
From _____ Inches To _____ Feet
From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch. 40	0.474"	0'	20'

Perforations:
Type perforation Factory Cut
Size perforation 0.030
From 20' feet to 30' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 17' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout Bentonic Clays
Gravel Packed: Yes No
From 17' feet to 30' feet

9. WATER LEVEL
Static water level 17' feet below land surface
Artesian flow NO G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 3-1, 2004
Date completed 3-1, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer for BOB LANGYEAR Co. Contractor
Address P.O. Box 1000 Dayton, NV. 89403 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148
Signed Phillip E. Cramer
By driller performing actual drilling on site or contractor
Date 3-9-04

Plugged by well log USE ADDITIONAL SHEETS IF NECESSARY 124279