WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92772
Permit No.
Basin 107

NOTICE OF INTENT NO. 48945

1. OWNER John Corona
MAILING ADDRESS 53 Spring Canyon Dr. Woodland Calif 96120
ADDRESS AT WELL LOCATION 90 Pinon Dr Smith NV 89430

2. LOCATION W ½ W ½ Sec. 10 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. ~~9-051-15~~ (Issued by Water Resources) | 9-051-15 (Parcel No.) | ~~Lyon~~ Valley View Estates (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy loam top soil	no	0	3	3
hard pan		3	7	4
alluvial D.G + brown clay		7	85	78
Coarse DG sand	yes	85	136	51
brown clay		136	148	12
Coarse DG sand	yes	148	160	12
Coarse sand + pea gravel	yes	160	185	25
gravel	yes	185	200	15

Date started Feb 6, 2004
Date completed Feb 14, 2004

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	12 ft	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
6 Inches		60 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	200

Perforations:
Type perforation Factory saw slots
Size perforation 1/16 X 3
From 150 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling Contractor
Address P.O. Box 92 Contractor
Smith Nev. 89430
Nevada contractor's license number issued by the State Contractor's Board 32166 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller By driller performing actual drilling on site or contractor
Date Feb 16 - 04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627