

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48941

1. OWNER Tom Properties ADDRESS AT WELL LOCATION 195 Sundance Ln, Smith Pk, 89430
MAILING ADDRESS P.O. Box 169, Smith Nevada 89430
2. LOCATION NW NW 1/4 Sec 7 T 11 N/S R. 24 S Lyon County
PERMIT NO. 10-401-18 Issued by Water Resources Parcel No. _____ Subdivision Name Sundance

3. New Well Replace Recondition Deepen Abandon Other _____
4. Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>sandy loam top soil</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>hard pan</u>		<u>2</u>	<u>6</u>	<u>4</u>
<u>sandy clay</u>		<u>6</u>	<u>64</u>	<u>58</u>
<u>sand + pb gravel</u>	<input checked="" type="checkbox"/>	<u>64</u>	<u>113</u>	<u>49</u>
<u>fine & coarse sand</u>	<input checked="" type="checkbox"/>	<u>113</u>	<u>140</u>	<u>27</u>

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet
HOLE DIAMETER (BIT SIZE)
From To
10 Inches 6 Feet 60 Feet
6 Inches 60 Feet 140 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>18 8</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation: factory saw slott
Size perforation: 1/2 X 3
From 90 feet to 140 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal _____
Placement Method: Pumped Poured
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 68 °F Quality good

Date started March 15 2004
Date completed March 18 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>7 ft</u>	<u>3 hrs</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling Contractor
Address P.O. Box 92, Smith Pk, 89430 Contractor
Nevada contractor's license number issued by the State Contractor's Board 32166A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller By driller performing actual drilling on site or contractor
Date March 18 - 04