

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 92776  
Permit No. \_\_\_\_\_  
Basin 071

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52432

1. OWNER City of Winnemucca ADDRESS AT WELL LOCATION Well #5  
 MAILING ADDRESS 90 W. 4th Street  
Winnemucca, NV 89445

2. LOCATION NE 1/4 SE 1/4 Sec. 29 T 36N N/S R 38E E Humboldt County  
 PERMIT NO. n/a Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Ran trimmie pipe to 270 ft. inside of 12 in column - pumped 21 yds. of 4% bentonite -neat cement through pump bowls. (pump bowls at 250 ft.) Pumped 7 more yds of 4% bentonite - neat cement. Neat cement at 217 ft. inside of pump column. Pumped 7 yds of 4% bentonite - neat cement. Filled rest of pump column-started filling annulus between pump column &amp; 16 in casing- pumped 3 more yds 4% bentonite-neat cement. Filled to top of casing. 82,516 lbs. of neat cement, 9,323 gallons of water, 4,450 lbs. of bentonite.</u>				
<u>Continued on next page</u>				

Date started 10/14/03 19\_\_\_\_  
 Date completed 10/16/03 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

From	To
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16"</u>				

Perforations:

Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 155 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2235

Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 10/25/03

RECEIVED  
OCT 27 2003  
STATE ENGINEER'S OFFICE

