

OFFICE USE ONLY
 Log No. 92815
 Permit No. _____
 Basin 230

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25660

1. OWNER Craig Makl ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS H.C. 70 Box 545-D 745 W. Bettles Rd
Amargosa Valley, NV 89020 Amargosa Valley, NV 89020
 2. LOCATION SE 1/4 NW 1/4 Sec 12 T. 17 N. R. 48 E. NVE County _____
 PERMIT NO. 19-121-30 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand w/ tan cly layers		0	65	65
Limestone		65	75	10
small yall - sand limestone	122	75	90	15
Sand		90	100	10
Limestone		100	135	35
Sand		135	145	10
sand w/ white cly	228	145	160	15
Limestone		160	175	15
Sandy cly		175	185	10
		185	200	15
Bottom of Well		200		

DCNR/DWR
 RECEIVED
 APR 14 2004
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	200
8	Steel	.188	0	7

Surface Protective Casing:
 Perforations: Machined
 Type perforation _____
 Size perforation 6R, .032 screen, #18 x 3 every 12"
 From 120 feet to 180 feet
 From 150 feet to 190 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 72 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 3A 2004
 Date completed 3/11 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Cook Drilling Co. Contractor
 Address H.C. 70, Box 543 Contractor
Amargosa Valley, NV 89020
 Nevada contractor's license number issued by the State Contractor's Board 5376-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
 Signed Reed Glad
 By driller performing actual drilling on site or contractor
 Date 4/9/04