WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92825
Permit No.
Basin 204

NOTICE OF INTENT NO. 25914

1. OWNER Jim Eisel
MAILING ADDRESS P.O. Box 58 Hanksville Utah 84734
ADDRESS AT WELL LOCATION 10 miles north of Ursine on Spring Valley Road

2. LOCATION N/E ¼ S/W ¼ Sec. 32 T. 3 N/S R. 70 E. Lincoln County
PERMIT NO. 0 (Issued by Water Resources) 06-071-01 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 17 | 17 |
| clay sand | | 17 | 135 | 118 |
| Sand - Boulders | | 135 | 149 | 14 |
| Hard Rock | | 148 | 150 | 2 |

well was muddy and very sandy
air lifted well to clean sand
free when finished

Date started 4-8-04, 19
Date completed 4-8-04, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 60 | 0 | 2 |

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 150 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | 0 | 150 |

Perforations:
Type perforation Torch Cut
Size perforation 1/8 x 6"
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 150 feet

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pump (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-8-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627