



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50691

1. OWNER Dayton Valley Golf Course ADDRESS AT WELL LOCATION Dayton Valley Golf Club
 MAILING ADDRESS 51 Palmer Dr 51 Palmer Dr
Dayton NV 89403 Dayton NV 89403
 2. LOCATION SW 1/4 SW 1/4 Sec. 17 T 16 NDS R 22 E County
 PERMIT NO. NEV 2001501 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Sand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Sandy clay Brown		1	8	7
Fine Sand Lt Brown		8	10	2
Sandy - clay Brown with red seams		10	37	27
Clay - Lt brown		37	39	2
Sandy clay		39	60	21
Sand with small gravels wet	top	60	65	5
Seam 64'-65'				
Fine sand - clay Lt brown dry		65	70	5
Fine sand moist		70	75	5
Course sand wet		75	90	15

3. WELL CONSTRUCTION
 Depth Drilled 90 Feet Depth Cased 90 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 Inches 0 Feet 90 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	70

Perforations:
 Type perforation Factory
 Size perforation 020
 From 70 feet to 90 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 68 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 68 feet to 90 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

Date started 4-1, 2004
 Date completed 4-1, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boart Longyear Contractor
 Address PO Box 1000 Contractor
Dayton NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources the on-site driller M-2223
 Signed Bruce Anderson
 By driller performing actual drilling on site or contractor
 Date 4-3-04