

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48562

1. OWNER Susan Bower ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 14595 Rancho Dr. Reno NV 89506 14595 Rancho Dr. Reno NV 89506  
 2. LOCATION SW 1/4 SW 1/4 Sec. 15 T. 23 N. 18 E. Washoe County  
 PERMIT NO. 0781118 Parcel No. \_\_\_\_\_ Subdivision Name Rancho Haven  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	15	15
Rock		15	90	75
Rock (Fract)		90	100	10
Rock		100	168	68
Rock (Fract)		168	180	12
Rock		180	192	12
Rock (Fract)		192	260	68

26 APR - 5 AM (11) 58  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
11 Inches 0 Feet 104 Feet  
8 3/4 Inches 104 Feet 260 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>3/16</u>	<u>2+</u>	<u>260</u>

Perforations:  
 Type perforation Saw slot  
 Size perforation 3/16  
 From 160 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 260 feet

9. WATER LEVEL  
 Static water level 5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 2/13/04  
 Date completed 3/17/04

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>140</u>	<u>6</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Olewski Drilling & Pump Co Contractor  
 Address 15045 Red Rock Rd Contractor  
Reno NV 89506  
 Nevada contractor's license number 50343  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1656  
 Division of Water Resources, the on-site driller  
 Signed John F. Olwski  
 By driller performing actual drilling on site or contractor  
 Date 4/4/04