WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92903
Permit No.
Basin 105

NOTICE OF INTENT NO. 49317

1. OWNER Robert & Joan Waugh
MAILING ADDRESS 1630 Valancia Ave.
Stockton, CA 95206

ADDRESS AT WELL LOCATION 2336 Genoa St. Genoa

2. LOCATION NE 1/4 SW 1/4 Sec. 9 T 13N N/S R 19E E Douglas County
PERMIT NO. (Issued by Water Resources) | Parcel No. 1319-09-602-006 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| On this date we abandoned a 6"X 162' well by Perforating with a Mills Knife at 4 around and at one foot intervals, We perforated from 147' to 90'. We then pumped 2 Cu. yards of neat cement mixed 5.2 gallons of water per sack.We pumped, using tremie pipe, from 162' to 90' then toped it off with 3/4 Cu. yard of cement grout to top of well. We then we cut off the top 2' of the well. | | | | |

RECEIVED 04 MAR -8 AM 10:57 STATE ENGINEERS OFFICE

Date started 3/4/2004, 19__
Date completed 3/4/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 162 Feet Depth Cased 162 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 162 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 162 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2159
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 3/4/04

USE ADDITIONAL SHEETS IF NECESSARY