



Log No. 92912
 Permit No. _____
 Basin 109

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51644

1. OWNER BRYAN L. MASINI ADDRESS AT WELL LOCATION Sweetwater Ranch, Sweetwater NV
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SW 1/4 Sec 9 T. 7 N/S R. 25 E Lyon Co County
 PERMIT NO. 13954 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MDA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravel</u>		<u>170</u>	<u>180</u>	<u>10'</u>
<u>Clay & Gravel</u>		<u>180</u>	<u>212</u>	<u>32'</u>
<u>Clay</u>		<u>212</u>	<u>260</u>	<u>48'</u>
<u>Gravel & Cobble & Boulders</u>		<u>260</u>	<u>600</u>	<u>340'</u>

8. WELL CONSTRUCTION
 Depth Drilled 170' Feet Depth Cased 600' Feet
 HOLE DIAMETER (BIT SIZE)
 From 15 1/4 Inches To 600' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12 3/4</u>	<u>33 lbs</u>	<u>.250</u>	<u>0</u>	<u>600'</u>

Perforations:
 Type perforation Sawed
 Size perforation 1/8 x 3 645 slots per foot
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 180' feet to 600' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal NOT KNOWN Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No NOT KNOWN
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 196' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Clean

Date started 2/18/04, 20____
 Date completed 2/25/04, 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Test Pump</u>	<u>1200 GPM</u>	<u>17 feet</u>	<u>7 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Arch Drilling Inc Contractor
 Address PO Box 558 Contractor
Silver Springs NV 89479
 Nevada contractor's license number issued by the State Contractor's Board 31841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
 Signed Michael S. Head
 By driller performing actual drilling on site or contractor
 Date 3/6/04

RECEIVED
 MAR -9 AM 10:22
 STATE ENGINEERS OFFICE