WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92913
Permit No.
Basin 103

NOTICE OF INTENT NO. 51641

1. OWNER T.A TARRELL
MAILING ADDRESS
ADDRESS AT WELL LOCATION 6565 Wildhorse Run Stagecoach 89429

2. LOCATION SW ¼ NE ¼ Sec. 7 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. N/A (Issued by Water Resources) 015-323-35 (Parcel No.) Iron Mtn. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & Gravel Clay		0	82'	82'
D-G Granite		82	120'	
Broken Granite Green Color Fault Hit.	–	120'	360'	240'

RECEIVED 04 MAR 11 AM 11:06 STATE ENGINEERS OFFICE

Date started 2-17-04, 20
Date complated 2-23-04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2-4	Copm	4 Hrs

8. WELL CONSTRUCTION
Depth Drilled 360' Feet Depth Cased 360' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	0 Feet	60' Feet
9 7/8 Inches	60' Feet	320' Feet
6" Inches	320' Feet	360' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	Class 200	21	320
4"	PVC	Sch 40	300'	360'
6 5/8	–	.188	+1	21'

Perforations:
Type perforation Sawed
Size perforation 1/8 x 4 . 4 Rows
From feet to feet
From 320' feet to 360' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 320' feet

9. WATER LEVEL
Static water level 167' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Dirty

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address PO 599 Contractor
Silver Spring NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed [signature] By driller performing actual drilling on site or contractor
Date 3/10/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627