WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92928
Permit No.
Basin 105

NOTICE OF INTENT NO. 51620

1. OWNER Chris Bonafede
MAILING ADDRESS 500 Mottsville Ln
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION ~~500 Mottsville Ln.~~ 570

2. LOCATION SE 1/4 NE 1/4 Sec. 02 T 12N N/S R 19E E Douglas County
PERMIT NO. Issued by Water Resources
1219-02-000-007 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown top soil		1	12	11
Gray clay		12	15	3
Brown coarse sand some gravel		15	55	40
Gray sand	X	55	75	20
Gray coarse & fine sand some gravel	X	75	135	60
Tan and brown sand some gravel	X	135	205	70

RECEIVED 04 APR -5 AM 11:51 STATE ENGINEERS OFFICE

Date started 3/1/2004, 19__
Date completed 3/5/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+		1.5

8. WELL CONSTRUCTION
Depth Drilled 205 Feet Depth Cased 205 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	205	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	205

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 145 feet to 165 feet
From 185 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 205 feet

9. WATER LEVEL
Static water level 1 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed
By driller performing actual drilling on-site or contractor
Date 3/9/04

USE ADDITIONAL SHEETS IF NECESSARY