WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92936
Permit No.
Basin 76
Ferntley
NOTICE OF INTENT NO. 94095

1. OWNER Tom's Gail Packer (Packer)
MAILING ADDRESS
N39514516 W119138982 NAD27
ADDRESS AT WELL LOCATION 1990 Alpine Drive (40 acre parcel) no street address as of 4-1-04 RC

2. LOCATION SE ¼ SE ¼ Sec 26 T 20 N/S R 25 E/W Lyon County
PERMIT NO. (Issued by Water Resources) 21-991-28 (Parcel No.) South highlands (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Reverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel Sand Boulders		0	10	
Gravel mix Clay		10	20	
Clay		20	41	
Gravel Cobbles		41	62	
		62	161	
Lose Circulation no Return		161	280	
Gravel Sand & Cemented		280	411	
Cemented Rock Lift Gravel Shaker		411	493	

~~Reclaimed/Repaired under NAC 534.789~~

Date started 1-30
Date completed 2-13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Produced about 15 GPM		

8. WELL CONSTRUCTION
Depth Drilled 493 Feet Depth Cased 493 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	100 Feet
7 7/8 Inches	100 Feet	280 Feet
6 Inches	280 Feet	493 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	280
4"	3.00	3/16	273	493

Perforations:
Type perforation Mill Slot
Size perforation
From 453 feet to 493 feet
From 453 feet to 493 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-20
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 298 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eggett Drilling Inc (Contractor)
Address P.O. Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0021841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed (By driller performing actual drilling on site or contractor)
Date 2/17/04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627