

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 92953
 Permit No. 52365
 Basin 61



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **52586**

1. OWNER **Barrick Goldstrike Mines** WVD97-3 ADDRESS AT WELL LOCATION **Barrick Goldstrike**
 MAILING ADDRESS **P.O. Box 29** minesite, north of Carlin, NV.
Elko, NV 89803

2. LOCATION SE 1/4 SE 1/4 Sec. 19 T 36N N/S R 50 E **Eureka** County
 PERMIT NO. 58355 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping abantonite via tremie from T.D. to 557', where it would rise no further. Poured hole plug while pumping abantonite to 97', hole plug to 20', and capped with neat cement.				
Quantities Used:				
Cement: 7.08 cu.ft.				
Hole plug: 75 cu.ft.				
Abantonite: 160 cu.ft.				

Date started 2/21/2004, 19
 Date completed 2/21/2004, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION
 Depth Drilled 805 Feet Depth Cased 801.6 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>16.75</u>	<u>0</u>	<u>20</u>	Feet
<u>9.875</u>	<u>20</u>	<u>805</u>	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.75</u>	<u>49.5</u>	<u>0.375</u>	<u>0</u>	<u>20</u>
<u>6.625</u>	<u>17</u>	<u>0.250</u>	<u>+2</u>	<u>801.6</u>

Perforations:
 Type perforation Louver
 Size perforation 0.125"

From	To	Feet
<u>119.3</u>	<u>801.6</u>	feet
		feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100.6 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100.6 feet to 805 feet

9. WATER LEVEL
 Static water level 557 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2210

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date 2/26/04

RECEIVED
 04 MAR 12 AM 10:20
 STATE ENGINEERS OFFICE

B.S.T.L