

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 92954
 Permit No. 58355
 Basin U

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **52585**

1. OWNER **Barrick Goldstrike Mines** AD97-4 ADDRESS AT WELL LOCATION **Barrick Goldstrike**
 MAILING ADDRESS **P.O. Box 29** minesite, north of Carlin, NV.
Elko, NV 89803

2. LOCATION SE 1/4 SE 1/4 Sec. 19 T 36N N/S R 50 E Eureka County
 PERMIT NO. 58355 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping abantonite via tremie from T.D. to 145', where it would rise no further. Poured hole plug while pumping abantonite to 115', pumped cement to 103', poured hole plug to 20', capped with neat cement.				
Quantities Used:				
Cement: 14.2 cu.ft.				
Hole plug: 51 cu.ft.				
Abantonite: 160 cu.ft.				

RECEIVED
 APR 12 AM 10:20
 STATE ENGINEERS OFFICE

Date started 2/20/2004, 19
 Date completed 2/20/2004, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION
 Depth Drilled 810 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>17.5</u>	<u>0</u>	<u>40</u>	<u>Feet</u>
<u>9.875</u>	<u>40</u>	<u>810</u>	<u>Feet</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.75</u>	<u>33.38</u>	<u>0.250</u>	<u>0</u>	<u>40</u>
<u>6.625</u>	<u>17.02</u>	<u>0.250</u>	<u>0</u>	<u>800</u>

Perforations:
 Type perforation Slot
 Size perforation 0.125"

From	To	feet to	feet
<u>117</u>	<u>800</u>		

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement Cement Grout Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 810 feet

9. WATER LEVEL
 Static water level 510 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1764
 Signed Paul Brider
 By driller performing actual drilling on-site or contractor
 Date 2/26/04

BSTA