WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

USE ADDITIONAL SHEETS IF NECESSARY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92982
Permit No. 68014
Basin 162

NOTICE OF INTENT NO. 26361

1. OWNER STEVE HAMRICK
MAILING ADDRESS 4801 S. PAHRUMP VALLEY BLVD
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4801 S. PAHRUMP VALLEY BLVD

2. LOCATION SW 1/4 SW 1/4 Sec. 2 T 21 N/S R 53 E NYE County
PERMIT NO. 68014 Issued by Water Resources
44-201-22 Parcel No.
RANCHO VALLEY ESTATES Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
COMMERCIAL
[X] ~~Domestic~~ [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	16	16
CALICHE		16	24	8
CLAY		24	45	21
CALICHE		45	55	10
CLAY		55	76	21
CALICHE	WB	76	84	8
CLAY		84	115	31
CALICHE	WB	115	120	5
CLAY		120	135	15
CALICHE	WB	135	148	13
CLAY		148	160	12
CALICHE	WB	160	175	15
CLAY		175	195	20
CALICHE	WB	195	220	25

Date started 4/14/2004 , 19__
Date completed 4/16/2004 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	220

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 120 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed [signature] By driller performing actual drilling on-site or contractor
Date 4/20/04