WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

USE ADDITIONAL SHEETS IF NECESSARY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92992
Permit No.
Basin 162

NOTICE OF INTENT NO. 26118

1. OWNER URSO
MAILING ADDRESS 4411 W. CHARLESTON PARK
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4411 W. CHARLESTON PARK

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T 20 N/S R 52 E NYE County
PERMIT NO. (Issued by Water Resources) 41-431-14 (Parcel No.) GOLDEN SPRINGS RANCH UNIT 2 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
CALICHE		6	20	14
CLAY		20	43	23
CALICHE		43	50	7
CLAY		50	80	30
CALICHE	WB	80	85	5
CLAY		85	115	30
CALICHE	WB	115	130	15
CLAY		130	145	15
CALICHE	WB	145	156	11
CLAY		156	160	4

DCNR/DWR
RECEIVED
APR 26 2004
LAS VEGAS OFFICE

Date started 4/15/2004, 19__
Date completed 4/19/2004, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	160

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 100 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed Ron Todd (By driller performing actual drilling on-site or contractor)
Date 4/20/04