

OFFICE USE ONLY
 Log No. 92994
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26109

1. OWNER DONNA JO EVANS ADDRESS AT WELL LOCATION 3081 W. WILSON
 MAILING ADDRESS 3081 W. WILSON
PAHRUMP, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 13 T 20 N/S R 52 E NYE County
 PERMIT NO. 28-633-06 CHARLESTON PARK RANCHOS UNIT 1
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____

4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE Rotary RVC Air Cable Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	6	6
CALICHE		6	14	8
CLAY		14	35	21
CALICHE		35	46	11
CLAY		46	65	19
CALICHE		65	72	7
CLAY		72	100	28
CALICHE	WB	100	112	12
CLAY		112	135	23
CALICHE	WB	135	146	11
CLAY		146	153	7
CALICHE	WB	153	160	7

DCNR/DWR
RECEIVED
APR 25 2004
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 160
10 Inches Feet Feet Feet
 _____ Inches Feet Feet Feet
 _____ Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	160

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From 100 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
 Contractor

Address P.O. BOX 4220
 Contractor
PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
 Signed Ron Tausk
 By driller performing actual drilling on-site or contractor
 Date 4/20/04

Date started 4/15/2004, 19
 Date completed 4/19/2004, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			