

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 93036  
 Permit No. \_\_\_\_\_  
 Basin 16

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **54386**

1. OWNER LARRY MENLEY ADDRESS AT WELL LOCATION 2713 LENORE  
 MAILING ADDRESS 2713 LENORE  
FALLON, NV 89406  
 2. LOCATION SE 1/4 NE 1/4 Sec. 21 T 19 N/S R 29 E CHURCHILL County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 007-391-56 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	
BROWN SAND		1	15	14
BROWN CLAY		15	17	2
BROWN SAND		17	35	18
BLACK SILT/CLAY		35	95	60
GRAY SAND		95	105	10
BROWN SAND(TANNINS IN WATER)		105	125	20
BROWN CLAY		125	128	3
GRAY SAND		128	180	52
GRAY SAND/CLAY		180	220	40
BROWN CLAY		220	230	10
GRAY SANDS/GRAVELS	X	230	253	23

RECEIVED  
 ON FEB 18 AM 10:59  
 STATE ENGINEERS OFFICE

Date started 1/23/2004 19  
 Date completed 1/26/2004 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		<u>1 HR</u>

8. WELL CONSTRUCTION  
 Depth Drilled 253 Feet Depth Cased 253 Feet  
 HOLE DIAMETER (BIT SIZE)  

	From	To
<u>10 3/4</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>6 1/8</u> Inches	<u>50</u> Feet	<u>253</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>253</u>

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080  
 From 247 feet to 252 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Seal Type:  
 Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 40'5" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WELSCO CORP. Contractor  
 Address P. O. BOX 888 Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199  
 Signed [Signature] By driller performing actual drilling on-site or contractor  
 Date 2/9/2004