

OFFICE USE ONLY
 Log No. 9305
 Permit No. 68207
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26811

1. OWNER Wortman Family Trust ADDRESS AT WELL LOCATION 4725 W. Maulding Ave. LV NEV. 89139
 MAILING ADDRESS Same

2. LOCATION SW 1/4 NW 1/4 Sec. 7 T. 22S N/S R 61 E Clark County
 PERMIT NO. 68207 74902 177-07-206-002, 014, 015
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Gravel		0	30	
Boulders & Gravel		30	310	
Cemented Gravel & Water xx		310	330	
Cemented Gravel		330	440	
Cemented Gravel & Water xx		440	475	
also permit # 75644				

8. WELL CONSTRUCTION
 Depth Drilled 475 Feet Depth Cased 475 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 475 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	50
6 1/2	PVC SRD		+1	475

Perforations:
 Type perforation Factory
 Size perforation .032 Sieve type
 From 415 feet to 455 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 277 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 4/13/04
 Date completed 4/19/04

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. Bonita Vista St. Contractor
Las Vegas, Nev. 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the 552 Division of Water Resources the on-site driller
 Signed V H Dimick
 By driller performing actual drilling on site or contractor
 Date 04-23-04