

WHITE - DIVISION OF WATER RESOURCES  
 CANARY - CLIENT'S COPY  
 PINK - WELL DRILLER'S COPY

USE ADDITIONAL SHEETS IF NECESSARY  
 STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 93093  
 Permit No. 162  
 Basin 162  
 NOTICE OF INTENT NO. 26355

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER JOE & IMELDA MARTIN ADDRESS AT WELL LOCATION 3750 S. SAGEBRUSH  
 MAILING ADDRESS 3750 S. SAGEBRUSH  
PAHRUMP, NV

2. LOCATION NE 1/4 SW 1/4 Sec. 31 T 20 N/S R 54 E NYE County  
 PERMIT NO. 41-143-16 CALVADA VALLEY UNIT 1  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	10	10
CLAY & GRAVEL		10	35	25
CALICHE		35	55	20
CLAY & GRAVEL		55	65	10
CLAY		65	78	13
CLAY & GRAVEL	WB	78	85	7
CLAY		85	96	11
CALICHE	WB	96	108	12
SANDY CLAY		108	118	10
CALICHE	WB	118	128	10
CLAY		128	135	7
CALICHE	WB	135	142	7
CLAY		142	155	13
CALICHE	WB	155	160	5

DCNR/DWR  
RECEIVED  
MAY 10 2004  
LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  

Inches	From	To	Feet
<u>10</u>	<u>0</u>	<u>160</u>	<u>160</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation SAWCUT  
 Size perforation 1/8 X 3

From <u>100</u> feet to <u>160</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal:  Yes  No  
 Depth of Seal 50

Placement Method:  Pumped  Poured

Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 70 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.  
Contractor

Address P.O. BOX 4220  
Contractor

PAHRUMP, NV, 89048  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063

Signed [Signature]  
 By driller performing actual drilling on-site or contractor

Date 5/3/2004

Date started 4/26/2004 .19  
 Date completed 4/30/2004 .19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		