

WHITE - DIVISION OF WATER RESOURCES
 CANARY - CLIENT'S COPY
 PINK - WELL DRILLER'S COPY

USE ADDITIONAL SHEETS IF NECESSARY
STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 93094
 Permit No. 162
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26362

1. OWNER JIM & JULIE CROW ADDRESS AT WELL LOCATION 980 INDOLE
 MAILING ADDRESS 980 INDOLE
PAHRUMP, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 33 T 20 N/S R 53 E NYE County
 PERMIT NO. 35-501-09 SILVER MOON RANCHETTES Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
CALICHE		6	15	9
CLAY		15	85	70
CALICHE	WB	85	88	3
CLAY		88	122	34
CALICHE	WB	122	130	8
CLAY		130	145	15
CALICHE	WB	145	158	13
CLAY		158	169	11
CALICHE	WB	169	175	6
CLAY		175	180	5

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 180 Feet
 From 0 Feet To 180 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From 120 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 63 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
 Signed Ron Torrey
 By driller performing actual drilling on-site or contractor
 Date 5/3/2004

Date started 4/26/2004, 19
 Date completed 4/30/2004, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DC/NR/DWR
 RECEIVED
 MAY 10 2004
 LAS VEGAS OFFICE