

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

USE ADDITIONAL SHEETS IF NECESSARY
STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 93096
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26356

1. OWNER MARK & CARLA CLAYTON ADDRESS AT WELL LOCATION: 9660 S. PARKO COURT
 MAILING ADDRESS 9660 S. PARKO COURT
PAHRUMP, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 36 T 21 N/S R 53 E NYE County
 PERMIT NO. _____ Parcel No. 44-851-14 Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	5	5
SAND & GRAVEL		5	10	5
SANDY CLAY & GRAVEL		10	45	35
CALICHE		45	56	11
SANDY CLAY & GRAVEL		56	75	19
SAND & GRAVEL	WB	75	200	125

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 200 Feet
10 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
 Type perforation SAWCUT
 Size perforation: 1/8 X 3
 From 100 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 66 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
 Contractor

Address P.O. BOX 4220
 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 5/3/2004

Date started 4/28/2004, 19____
 Date completed 4/30/2004, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DCNR/DWR
RECEIVED
MAY 10 2004
LAS VEGAS OFFICE