WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

USE ADDITIONAL SHEETS IF NECESSARY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93099
Permit No.
Basin 162

NOTICE OF INTENT NO. 26114

1. OWNER NEILS CHRISTIANSEN
MAILING ADDRESS 171 E. EMBER
PAHRUMP, NV

ADDRESS AT WELL LOCATION 171 E. EMBER

2. LOCATION SW 1/4 SW 1/4 Sec. 34 T 20 N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 40-701-05 (Parcel No.) CALVADA VALLEY UNIT 4A (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
CLAY		0	15	15
CALICHE		15	23	8
CLAY		23	75	52
CALICHE	WB	75	81	6
CLAY		81	115	34
CALICHE	WB	115	123	8
CLAY		123	140	17
CALICHE	WB	140	145	5
CLAY		145	156	11
CALICHE	WB	156	165	9
CLAY		165	170	5
CALICHE	WB	170	180	10

DCNR/DWR
RECEIVED
MAY 10 2004
LAS VEGAS OFFICE

Date started 4/27/2004, 19__
Date completed 4/30/2004, 19__

7. **WELL TEST DATA**

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 100 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. **WATER LEVEL**
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed Ron Torres (By driller performing actual drilling on-site or contractor)
Date 5/3/2004