COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93107
Permit No. 56387
Basin 212

NOTICE OF INTENT NO. 26192

1. OWNER MCNAMEE FAMILY
MAILING ADDRESS 8101 RACEL ST.
LAS VEGAS, NV 89131-1401

ADDRESS AT WELL LOCATION 8101 RACEL ST
LAS VEGAS, NV

2. LOCATION SE ¼ SW ¼ Sec 09 T 19 S R 60 E CLARK County

PERMIT NO. 56387 (Issued by Water Resources) | 125-09-401-027 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty brown clay		60	135	75
and rock.				
Silty red brown		135	191	56
Silty gray clay	x	191	210	19
Brown clay		210	245	35
Pea gravel	xx	245	270	25
Hard clay		270	325	55
Pea gravel	x	325	331	6
Cemented		331	500	169

DCNR/DWR
RECEIVED
MAY 10 2004
LAS VEGAS OFFICE

Date started 3/24, 20 04
Date completed 3/29, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
18	Inches	0	Feet	60	Feet
12	Inches	60	Feet	500	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.38	.250	-1	60
8 5/8	16.94	.188	-2	500

Perforations:
Type perforation Machine
Size perforation 2.5x3/16 24 slate per ft.
From 200 feet to 300 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☐ Yes ☐ No
From _____ feet to _____ feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 168 feet below land surface
Artesian flow _____ G.P.M _____ P.S.I
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed [signature] By driller performing actual drilling on site or contractor
Date 4/29/04

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com